

**CERTIFICATE OF CONFORMITY – Electrical Cabinets**

We certify that the MODEL and PRODUCTS listed below have been manufactured in accordance with Quality Management System procedures to meet the requirements of relevant STANDARDS and the requirements of the listed PROTECTION RATING.

**MODEL:**

MFS – Floor Standing Electrical Cabinet, Steel

**PRODUCTS:**

IP-MFS1624040-KIT	IP-MFS1624060-KIT	IP-MFS1624080-KIT	IP-MFS1626040-KIT
IP-MFS1626060-KIT	IP-MFS1626080-KIT	IP-MFS1628040-KIT	IP-MFS1628060-KIT
IP-MFS1628080-KIT	IP-MFS16210080-KIT	IP-MFS1864040-KIT	IP-MFS1864060-KIT
IP-MFS1864080-KIT	IP-MFS1866040-KIT	IP-MFS1866060-KIT	IP-MFS1866080-KIT
IP-MFS1868040-KIT	IP-MFS1868060-KIT	IP-MFS1868080-KIT	IP-MFS18610060-KIT
IP-MFS18610080-KIT	IP-MFS18612040-KIT	IP-MFS18612060-KIT	IP-MFS18612080-KIT
IP-MFS2024040-KIT	IP-MFS2024060-KIT	IP-MFS2024080-KIT	IP-MFS2026040-KIT
IP-MFS2026060-KIT	IP-MFS2026080-KIT	IP-MFS2028040-KIT	IP-MFS2028060-KIT
IP-MFS2028080-KIT	IP-MFS20210060-KIT	IP-MFS20210080-KIT	IP-MFS20212060-KIT
IP-MFS20212080-KIT			

**STANDARDS (& CONFORMITIES):**

IEC/EN 60529, IEC/EN 62208, IEC/EN 61439, CE, UKCA

**PROTECTION RATING:**

IP55, IK10

**CERTIFICATES:**

IEC 60529 Degrees of protection provided by enclosures: Certificate AB-0386-T 1902.14 01/00

IEC/EN 62208 Empty Enclosures for low-voltage switchgear and controlgear assemblies: Certificate 0366932-TSE-01/01

IEC/EN61439-1, 61439-2 Low Voltage Switchgear and Controlgear Assemblies: Certificate 0406176-TSE-02/01

CE Certificate of Compliance: Certificate SZL-21 MA 13338-1

UKCA Certificate of Compliance: Certificate SZU-22MA19560-1

Products are manufactured to Quality, Safety and Environmental standards. In the event that any amendments or modifications to the product or assembly are not explicitly agreed with us, this Certificate of Conformity shall be invalidated.

IP ENCLOSURES PTY LTD

Revision: August 20, 2024